

Water Hammer Arresters

Standard PDI-WH 201

Revised 2006

- Certification
- Sizing
- Placement
- Reference Data



THE PLUMBING AND DRAINAGE INSTITUTE

800 Turnpike Street, Suite 300

North Andover, MA 01845

Phone: (800) 589-8956

Fax: (978) 557-0721

Web: www.pdionline.org

E-mail: pdj@pdionline.org

©2006 The Plumbing and Drainage Institute

The Standard is not intended to be limiting in any way, but rather is intended to provide a uniform measure of performance by Water Hammer Arresters. The use of this Standard is voluntary and the issuance or existence of this Standard does not in any respect prevent or restrict any member or nonmember of The Plumbing and Drainage Institute from manufacturing or supplying products that do not meet the performance criteria contained in the Standard. The data in this publication are based on information believed to be reliable and are offered in good faith but without guarantee. The Plumbing and Drainage Institute and its member companies assume no responsibility or liability for the use of this Standard. No warranty, express or implied, is made of the information contained in this Standard by The Plumbing and Drainage Institute or by any of its member companies.

FOREWORD

The Plumbing & Drainage Institute is an association of companies engaged in the manufacture of plumbing products. The Institute is dedicated to the advancement of engineering and manufacture of plumbing products.

TABLE OF CONTENTS

WATER HAMMER	4
Definition	4
Reaction	4
Cause	4
Shock Intensity	4
Shock Wave	5
Water Hammer Noise	5
System Protection	5
Graphic Illustration of a Shock Wave	6
 Means of Control	 7
Air Chamber	7
Calculated Air Chambers	7
Importance of Shock Control	7
Reference	7
 Performance	 9
Example of Failure	9
Replenishment of Air	9
 ENGINEERED WATER HAMMER ARRESTERS.....	 11-12
Engineered Devices.....	11
Types	11
Design and Construction	11
Calculated Air Chamber.....	11
Performance Comparison Calculated Air Chamber vs.P.D.I. Water Hammer Arrestor	11
Performance Test	12
Endurance Test	12
 THE ROLE OF PDI.....	 13
 CERTIFICATION TESTING EQUIPMENT	 14
Testing Equipment	14
Testing Procedure.....	14
Certification Testing Equipment	15
Certificate of Compliance	16
Use of P.D.I. Certification Mark	16

TESTING FOR THE RIGHT TO USE PDI CERTIFICATION MARK	17
Visual Inspection	17
Physical Test.....	17
Water Hammer Arrestor Certificate.....	18

SIZING AND PLACEMENT DATA .	19-25
Standardization	19
Symbols	19
Single & Multiple Fixture Branch Lines	19
Definition of Fixture-Unit	19
Sizing and Placement Data	19
Long Runs of Piping to Equipment.....	24
Long Runs of Piping	24

APPENDIX A.....	26
Recommended Rules for Sizing the Water Supply System	26
Preliminary Information.....	26
Demand Load.....	27
Permissible Friction Loss.....	28
Size of Building Supply	28
Size of Principal Branches and Riser	29
General.....	29
Example	29

Sizing Water Systems	30-35
Estimated Curves for Demand Load.....	30
Enlarged Scale Demand Load.....	30
Friction Loss in Head- Smooth Pipe	31
Friction Loss in Head- Fairly Smooth Pipe....	32
Friction Loss in Head- Fairly Rough Pipe	33
Friction Loss in Head- Rough Pipe.....	34
Fixture-Unit Listings.....	35

Definitions.....	36
-------------------------	-----------

WATER HAMMERS

The term “Water Hammer” is well known to engineers, contractors, maintenance personnel and other persons engaged in the plumbing and piping industry. Ever since water was first conveyed by a piping system, the destructive forces and hammer-blow sounds, associated with “Water Hammer” have caused annoyances, inconvenience and costly damage. The purpose of this manual is to present an exhaustive study of water hammer and tested methods by which it can be completely controlled.

Definition

Water hammer is the term used to define the destructive forces, pounding noises and vibration which develop in a piping system when a column of non-compressible liquid flowing through a pipe line is stopped abruptly. The tremendous forces generated at the point of stoppage can be compared, in effect, to that of an explosion.

Reaction

When water hammer occurs, a high intensity pressure wave travels back through the piping system until it reaches a point of some relief such as a large diameter riser or piping main. The shock wave will then surge




Figure 1:

back and forth between the point of relief and the point of impact until the destructive energy is dissipated in the piping system. This violent action accounts for the piping noise and vibration.

Cause

The common cause of shock is the quick closing of electrical, pneumatic, spring loaded valves or devices, as well as the quick hand closure of valves or fixture trip. The speed of the valve closure time, especially during the last 15% of valve closure, is directly related to the intensity of the surge pressure.

Shock Intensity

Quick valve closure may be defined as a closure equal to or less than $\frac{2L}{a}$ seconds.

Maximum pressure rise will follow.

This pressure rise can be calculated by the following, known as Joukowsky's formula:

$$pr = \frac{wav}{144g} \text{ (p.s.i.)}$$

Where

pr = pressure rise above flow pressure, p.s.i

w = specific weight of liquid, lbs./ft.³ (62.4 water)

a = velocity of pressure wave, ft./sec. (4000-4500 average for water)

v = change in flow velocity, ft./sec.

g = acceleration due to gravity, ft./sec.² (32.2)

L = length of pipe (ft.) from point of valve closure to point of relief (see definition of Point of Relief, Page 36)

This action will produce an approximate pressure rise of 60 times the velocity. Engineers generally employ a velocity between 5 and 10 feet per second which may produce a shock pressure of 300-600 p.s.i.

Shock Wave

The resultant water hammer shock wave travels back and forth in the piping, between the point of quick closure and the point of relief, at a rate of 4000-4500 feet per second. Graphic illustrations of a shock wave are shown in Fig. 2. In this illustration it will be noted that the shock wave alternately expands and contracts the piping during its occurrence. This is the destructive force which may cause any of the following conditions.

- Ruptured Piping
- Leaking Connections
- Weakened Connections
- Pipe Vibration and Noise
- Damaged Valves
- Damaged Check Valves
- Damaged Water Meters
- Damaged Pressure Regulators and Gauges
- Damaged Recording Apparatus
- Loosened Pipe Hangers and Supports
- Ruptured Tanks and Water Heaters
- Premature Failures of Other Equipment and Devices

Water Hammer Noise

Although noise is generally associated with the occurrence of water hammer it can occur without audible sound. Quick closure always creates some degree of shock - with or without noise. Therefore, the absence of noise does not indicate that water hammer or shock is nonexistent in a water distribution system.

System Protection

Water hammer arresters prolong the service life of piping, valves, fittings, trim, equipment, apparatus and other devices which are part of a water distribution system.




Figure 2:

MEANS OF CONTROL


In order to reduce shock pressure and confine its action to the section of piping in which it occurs, a suitable means of control must be provided to absorb and dissipate the energy causing the shock. Air or gas is the most effective medium that can be used for this purpose since it is highly compressible.

Air Chamber

For many years the air chamber has been utilized as one means for controlling shock. The unit consists of a capped piece of pipe, the same diameter as the line it serves, and its length ranges between 12" and 24". The air chamber has been constructed in several different shapes. See Figures 3, 4, 5, 6.

Comments

The plain air chambers (Fig. 3 and Fig. 4) are generally placed on the supply lines to fixtures or equipment. A standpipe type of air chamber (Fig. 5) is generally placed on a piping main. A rechargeable type of air chamber (Fig. 6) is generally placed at the end of a branch line or on a piping main.



Figures 3, 4, 5 & 6:

These air chambers shown in the diagram, are made of pipe and fittings. However, unless such devices are of the correct size and contain a prescribed volume of air, they cannot be regarded as suitable even for the temporary control of shock.

Calculated Air Chambers

In order for an air chamber to adequately control shock, it must be of sufficient proportions and possess a prescribed displacement capacity of entrapped air. If correctly sized, an air chamber may temporarily reduce the maximum shocks occurring in a line to a safe pressure.

Importance of Shock Control

Most valves and fittings used in plumbing water distribution systems are designed and constructed for normal maximum rated pressures of 150 P.S.I.G. Therefore, unless an air chamber can reduce shock pressures to some degree less than 150 P.S.I.G., serious damage to the valves, fittings and other components of the piping system may result. The commonly used air chamber, even when correctly sized, only controls shocks temporarily after it is initially installed.

Reference

F.M. Dawson and A.A. Kalinske, of the Iowa Institute of Hydraulic Research, in their technical bulletin No. 3 titled "Water Supply Piping For the Plumbing System" indicated the recommended volume of air chambers for varied conditions of pipe size, length of run, flow pressure and velocity. Table 1, based upon information supplied by these authorities, lists examples of air chambers required for several conditions.

Comment

From the examples below, it should be apparent that excessively large air chambers and fittings are required for the temporary control of

shock. The ordinary, inadequately sized air chambers which are generally installed do not possess the capacity needed even for the temporary control of shock.

TABLE I

Nominal Pipe Diameter	Length of Pipe (Ft.)	Flow Pressure P.S.I.C.	Velocity in Feet Per Sec.	Required Air Chamber	
				Volume in Cubic inches	Physical Size in inches
1/2"	25	30	10	8	3/4" x 15"
1/2"	100	60	10	60	1" x 69.5"
3/4"	50	60	5	13	1" x 15"
3/4"	200	30	10	108	1-1/4" x 72.5"
1"	100	60	5	19	1-1/4" x 12.7"
1"	50	30	10	40	1-1/4" x 27"
1-1/4"	50	60	10	110	1-1/2" x 54"
1-1/2"	200	30	5	90	2" x 27"
1-1/2"	50	60	10	170	2" x 50.5"
2"	100	30	10	329	3" x 44.5"
2"	25	60	10	150	2-1/2" x 31"
2"	200	60	5	300	3" x 40.5"

PERFORMANCE

Although a correctly sized air chamber will temporarily control shock to within safe limits of pressure, its performance is effective only while the air chamber retains its initial charge of air. The air, however, is readily lost. See Figures 7, 8, 9, 10.

Comments

As shown, the air charge can be depleted during the flow cycle since water is drawn from all directions. Moreover, the entrapped air is also diminished by turbulence. During this process, the water absorbs the air, and as the unit becomes waterlogged, it loses its ability to absorb shock.

Examples of Failure

An air chamber, sized by the Dawson Method, will control shock to limits that do not exceed 150 P.S.I.G. Tests were conducted by the United States Testing Laboratory to determine the elapsed time for an air chamber to exceed 150 P.S.I.G. and in addition, the elapsed time for failure, as evidenced by a violent pounding and vibration in the piping system (see Table II). The conditions of testing were 60 P.S.I.G. flow pressure with a velocity of 10 feet per second.

The tests were run at the rate of 4 valve closures per minute or approximately 1900 valve closures per day. In each case, length of line is 50 feet.

Replenishment of Air

It is a popular belief that the air chambers serving a group of fixtures can be replenished with air merely by closing the control valve on the branch line and opening the fixture trip. Actually, it is impossible to replenish the air by this method, as shown by the illustrations in Fig. 11.




Fig. 7

Fig. 8

Fig. 9

Fig. 10

Figures 7, 8, 9 & 10

Unit	Cu. In. Capacity	Line Size	Dia. of Air Chamber	Height of Chamber	Failure	
					Exceeded 150 P.S.I.G.	Total
1	30	1/2"	3/4"	56.7"	1st hour	2nd day
2	50	3/4"	1"	58.2"	1st hour	3rd day
3	75	1"	1-1/4"	50.0"	1st hour	2nd day
4	110	1-1/4"	1-1/2"	54.0"	1st hour	2nd day
5	170	1-1/2"	2"	50.5"	1st hour	1st day
6	300	2"	3"	40.5"	1st hour	2nd day

Table II: Correctly Sized Air Chambers

Comment

As shown in Figures 11(a) & 11(b), the supply piping forms a trap. Therefore it is impossible to drain sufficient water from the piping to allow air to enter. Regardless of how the piping is rearranged, within practical limitations, there is no possible way to introduce air. Only by opening the fixture trap and draining all the branch lines and risers can air be introduced.

It is recognized that a correctly sized air chamber, when initially charged with gas or air at atmospheric pressure, can control water hammer. It has been established the air chamber fails rapidly in an actual installation, (see Table II, page 9). Thus an air chamber cannot be an effective means for the control of shock.




Figure 11:

(a) ELEVATION – Showing the arrangement of cold and hot water piping for a group of lavatories. Note the air chambers on the cold and hot water supplies to each lavatory.
(b) SECTION – Showing the arrangement of supply piping to lavatory.

ENGINEERED WATER HAMMER ARRESTERS

Engineered Devices

Engineered devices also use gas or air to control water hammer. The gas or air, however, is permanently sealed in the unit. This feature enables the engineered device to control shock for many years.

Types

Different styles of engineered devices are on the market. While the basic principle of operation in each unit is somewhat different, each unit is designed with the permanent cushion of gas or air needed to control shock.

Design and Construction

A water hammer arrester must have the capacity to control shock adequately. The construction must be of a quality that will enable the unit to provide many years of dependable service.

Calculated Air Chamber

The performance results for a calculated air chamber and an engineered water hammer arrester as obtained in testing are compared in Figs. 12 and 13 respectively.

Comments

Conditions of this test: a 50' length of 1/2" pipe with flow pressures at 60 P.S.I.G. and flow velocity at 10 F.P.S. The intended duration of this test was 5000 cycles

with water at ambient temperature. The calculated air chamber was constructed of 3/4" pipe, 56.7" long and capped at one end. This air chamber initially controlled the shock to a limit of just under 150 P.S.I.G. However, this unit permitted a pressure higher than 150 P.S.I.G. within the first 250 cycles of testing and rapidly failed in performance as it reached a pressure in excess of 250 P.S.I.G. after approximately 4400 cycles of testing. Once the pattern of failure had been established, the testing was stopped to avoid needless damage to test equipment.

P.D.I. Water Hammer Arrester

Comments

A manufactured water hammer arrester certified as a P.D.I. "A" unit was subjected to the same test and conditions as described for the calculated air chamber. This unit controlled the shock to a limit of well under 150 P.S.I.G. for 5000 cycles of testing with water at ambient temperature. The same device was then subjected to an additional 5000 cycles of testing with hot water at 180°F and still continued to control the surge to well under 150 P.S.I.G.

Graphic Illustration

The curves in Fig. 14 clearly indicate the initial, as well as the permanent, effectiveness of a P.D.I. certified water hammer arrester (curve 5) compared to other devices utilized for the prevention of water hammer.




Figure 12: Calculated air chamber

Explanation of Fig. 14 (Curves 1 to 5)

- 1 - Represents a commonly used air chamber. It is 24" in height and is one pipe size larger than the line served. Initially, it controlled the surge at approximately 240 P.S.I.G. but its control gradually becomes less as shown.
- 2 - Represents a manufactured unit (not certified). Initially it controlled the surge at approximately 210 P.S.I.G. and gradually its control failed as shown. The dotted lines project the estimated rate of failure after 5000 cycles of actual testing.
- 3 - Represents a manufactured unit (not certified). Initially it controlled the surge at approximately 185 P.S.I.G. and its control continued to fail, as shown. The dotted lines project the estimated rate of failure after 5000 cycles of actual testing.

- 4 Represents the average performance of calculated air chambers that initially controlled the surge at approximately 145 psi. but rapidly failed as shown
- 5 - Represents the performance of a typical P.D.I. unit which initially controlled the surge under 150 P.S.I.G. and maintained this measure of control for 10,000 cycles of testing.

Comments

Although the duration of the above test was 10,000 cycles, P.D.I. units have proven their capability to endure testing under equal conditions involving many hundreds of thousands of cycles of shock, and continues to control the maximum surge to 150 P.S.I.G. or less.




Figure 13: P.D.I. Water hammer arrester




Figure 14: Comparative endurance tests



THE ROLE OF PDI

The members of the Plumbing and Draining Institute have been interested in the cause and control of Water Hammer. Therefore, they engaged in an exhaustive study of this phenomena. The performance of air chambers and engineered arresters was ascertained by extensive testing at a test facility located at the United States Testing Company laboratory in Fairfield, New Jersey. The long term benefit of installing engineered Water Hammer Arresters in place of air chambers is described in the next section.

Recognizing the toll imposed on the test facility by decades of service and the need for improvements, the Institute, after consultation with noted hydraulics authorities, revised the facility to its current configuration, described in Figure 15. Capitalizing on the experience gained by monitoring water hammer arresters in service since the inception of the program, the test facility has undergone a major upgrade to provide optimum performance and total dependability.

The test facility has a computer data acquisition and control system. Computer control allows calibration to be done initially and every 100 endurance cycles and automatically determines exact flow needed. That flow is established by means of a positive displacement gear pump with adjustable speed drive (Fig. 15 item 5). The flow is monitored with a flow meter (Fig. 15 item 26) and the computer automatically adjusts the speed drive each cycle to obtain consistent flow. The flow pressure is established by means of the air pressure in the two 30 gallon pneumatic water tanks (Fig. 15 item 9). The computer measures the flow pressure by means of

the flow transducer (Fig. 15 item 19) and adjusts each cycle by opening the fill or vent valves (Fig. 15 item 10). Valve shut off time is calculated by computer analysis of data each cycle to ensure it is less than the 25 millisecond maximum. The computer measures the temperature of the flow and ensures that the water heater (Fig. 15 item 2) is maintaining the temperature. The ambient temperature tests are done between ambient and at most 10 degrees F over ambient and can be held in such a close range of temperature due to the redesign of the system. Computer control has also made possible the elimination of noise from data signals by means of a 2.5 millisecond moving average of data, an improvement over an unfiltered oscillogram. Developmental testing benefits from having a record of test variables for each test cycle of the endurance test in addition to individual shock dampening graphs and from shut down of testing should this be necessary as soon as prescribed limits are exceeded. It is also possible to provide data from testing in electronic format.

Any manufacturer, whether or not a P.D.I. member, may have their units tested by a qualified independent testing laboratory for certification in accordance with Standard PDI-WH201. For further information on this subject, as well as with reference to use of the Institute's Certification Mark and participation in its annual visual inspection and physical test program see pages 16 and 17.

CERTIFICATION TESTING

Introduction

This test procedure has been developed (1) to provide the industry with a standard method of rating water hammer arresters, (2) to establish a minimum standard for design and manufacture of any unit with respect to its serviceability in the water distribution system. The test methods simulate actual service conditions and provide reproducible results so that any engineered water hammer arrester can be tested for compliance with the standard.

Testing Equipment

The test facility is designed to subject the test unit to the full energy imposed by the abrupt stoppage of a 50 foot column of water. The water is flowing in a standard schedule 40 steel pipe exerting a total pressure not to exceed 250 P.S.I.G. for the AA size, and 400 P.S.I.G. for sizes A through F. This arrangement is shown in Figure 15. In order to insure reproducible test results, the following tolerances must be maintained:

1. Surge valve (22) - flow termination not to exceed 25 milliseconds
2. Flow pressure ± 0.5 P.S.I.G.
3. Total pressure ± 10 P.S.I.G. (surge plus flow).
4. Pressure transducer smallest incremental reading 2 P.S.I.G.

Testing Procedure

Seven categories have been established to cover the normal range of sizes required to protect the water distribution system of any building. Table III lists these sizes together with the corresponding test conditions under which each must qualify.

Each unit to be tested shall be installed in the test facility, item 21 of Figure 15, and shall use the corresponding sized test pipe (16). The motorized ball valve (20) shall be moved to the closed position and the pump energized to fill the system with water and purged of air. The test pipe shall be fully supported to avoid high spots where air may be trapped. Pressure gages, valves, and fittings must be purged of air. The test unit is then filled with water in the inverted position. In test units containing an orifice, the fill tube must be inserted in the orifice to eliminate the possibility of trapping air in the bellows convolutions. The filled inverted unit is then capped with a thin plate and, with the plate held firmly in place, rotated to the normally installed position and placed on the brimming ball valve fitting. The plate is slipped out from its position between the test unit and the ball valve as the test unit is threaded into the ball valve and secured in place. The test conditions are then established.


TABLE III

P.D.I. Size	Pipe Size	Pipe Length (ft.)	*Total Pressure - Flow + Surge Less Arrester (P.S.I.G.)	*Max. Reduced Pressure Flow + Surge with Arrester (P.S.I.G.)
AA	1/2"	50	250	160
A	1/2"	50	400	150
B	3/4"	50	400	150
C	1"	50	400	150
D	1-1/4"	50	400	150
E	1-1/2"	50	400	150
F	2"	50	400	150

*The total pressure and maximum reduced pressure shall be defined as the highest of any 2.5 millisecond average pressure measured during the calibration and testing procedure.

The test unit will have passed the endurance test by comparing 10,000 cycles without the reduced pressure exceeding 160 P.S.I.G. for any 10 consecutive cycles at any time during the endurance test.

CERTIFICATION TESTING EQUIPMENT



LISTING OF EQUIPMENT

- | | |
|--|---|
| 1 – Sump tank 4' dia. x 4½' high – 450 gallon | 14 – Float vent air bleed installed at top of return bend |
| 2 – Water heater | 15 – 2" ball valve |
| 3 – Shutoff valves | 16 – Test length steel pipe (sizes 2", 1½", 1¼", 1", ¾" and ½" to fit between A1 and A2 |
| 5 – Gear pump with adjustable speed drive, computer controlled | 17 – Dynamic pressure transducer, Kistler Model 212B3 Piezotron |
| 6 – Pressure relief valve | 18 – Solenoid valve |
| 7 – 2" pipe | 19 – Static pressure transducer |
| 8 – Two 2" gate valves for inlet to pneumatic tanks | 20 – Actuated ball valve, same size as test pipe |
| 9 – Two 30 gal. pneumatic water tanks (12" dia.), one with 24" sight glass | 21 – Water hammer arrester test unit |
| 10 – ½" air line with automatic fill & vent valves | 22 – 1½" pneumatically actuated surge valve |
| 12 – 3" gate valves | 23 – 2" solenoid valve |
| 13 – 10" return bend 36" between centers | 24 – 2" metering valve |
| | 25 – ½" metering valve |
| | 26 – Flow transducer |
| | 27 – 2" pipe line |

Figure 15:

The pump (5) is energized to circulate water through the system with the solenoid valve (18) open to the transducer (19). The required flow rate and flow pressure (60 P.S.I.G.) are established and maintained by a computerized data acquisition and control system. This system also operates the quick closing hydraulic surge valve (22) and measures the magnitude of the resulting shock wave. Ten (10) calibration cycles will be conducted initially with valve (20) closed in order to ascertain that a surge pressure of 340+/-10 P.S.I.G. for sizes A through F (or 190+/-10 P.S.I.G. for size AA) at a flow pressure of 60+/-0.5P.S.I.G. is obtained. At least three (3) such calibration cycles shall be conducted after every 100 cycles. The test unit is then exposed to the cyclic test by opening valve (20) and isolating the flow transducer (19) by closing valve (18)

The unit shall be subjected to 5,000 cycles of shock testing with water at ambient temperature. The same unit shall be subjected to an additional 5,000 cycles of shock testing with water at 180 degrees F. minimum. The total pressure shall be recorded after each cycle. The unit shall be certified if no ten consecutive cycles exceed 160 P.S.I.G. total pressure.

Certificate of Compliance

A certificate of compliance may be issued by a qualified independent testing laboratory

for a water hammer arrester only after the unit has been successfully tested for performance and endurance in the manner prescribed herein. The certificate must be the equivalent of the example shown in Fig. 16. The description on the certificate shall be adequate for identification of the product. Upon further certification by the manufacturer that its current production units which are of the same size, type or model as the unit tested are identical thereto then such manufacturer may represent such units were "Tested in _____(year) and complied with PDI-WH-201" so long as such units are in fact demonstrated, upon proper demand, to be identical in the relevant respects considered in PDI WH-201 as of the year the representative unit was tested but may not claim such units to be certified by the Plumbing and Drainage Institute or use its Certification Mark.

Use of P.D.I. Certification Mark

Only water hammer arresters which are certified by the manufacturer as being identical in the relevant respects considered in P.D.I. WH-201 to the unit tested and certified as above detailed by an independent laboratory approved by the Institute may bear the Institute's Certification Mark as exemplified in Fig. 16A provided such manufacturer also executes the Institute's current standard Certification Mark License Agreement.



Figure 16A:



TESTING FOR THE RIGHT TO USE PDI CERTIFICATION MARK

In an effort to assure continued compliance with Standard PDI-WH201, a program has been established.

Annual Visual Inspection - Physical Test Program

Within three years from the date of original certification and yearly thereafter, each manufacturer must resubmit two units, size to be designated by the Institute, along with a complete set of current detailed drawings, to the qualified independent testing laboratory approved by the Institute which previously tested the units, for a visual inspection and a physical test to be made as follows:

Visual Inspection

One unit must be cut in half on a bandsaw or other means so that the interior can be observed and compared to the drawings in respect to physical size and shape. The materials must be observed in respect to material specifications. If

materials do not appear to be the same as specified, further analytical tests must be conducted.

Physical Test

The other unit must be given a performance test according to procedures outlined in Standard PDI-WH201.

1. The inspected and tested units, and their detailed drawings must be properly labeled and retained for future reference and comparisons.
2. Any discrepancies found must be referred to the Executive Secretary of the PDI who, in turn, shall notify the manufacturer and the PDI engineers for evaluation and recommendations for action to be taken by the Institute.
3. The manufacturer must obtain a Statement of Compliance that the water hammer arresters met all of the requirements outlined in the Standard PDIWH201 for the Annual Visual Inspection - Physical Test Program.


(Name of Independent Testing Laboratory) (Street, City, State and Zip Code)	
WATER HAMMER ARRESTER CERTIFICATE SIZE AA THRU F	
<p>This is to certify that a production Water Hammer Arrester, Model No. _____, manufactured by, or for _____, which conforms to the drawings and dimensions illustrated herein, has been tested by us as of this date in accordance with the testing procedures established by the Plumbing and Drainage Institute, in P.D.I. Standard WH-201, for size _____ Water Hammer Arresters. We further certify that when such arrester was tested on a _____ inch pipe line of fifty feet effective length, flow pressures of 60 P.S.I.G. and surge pressure of 340 P.S.I.G. (400 P.S.I.G. maximum total pressure) such arrester limited the total pressure created by sudden valve closure to 160 P.S.I.G. maximum which is the acceptable limit to such Standard.</p> <p>The results of tests conducted on this unit are applicable to this unit only. Use of this data and/or reference to the Plumbing Drainage Institute or the above named laboratory in connection with purported certification by any other means than testing to the applicable standard without the consent of the Plumbing Drainage Institute will constitute a breach of the relevant certification Mark License Agreement with the Plumbing Drainage Institute.</p>	
(Drawing, dimensions and description)	
Subscribed and swore to (or affirmed) before me at _____ this ____ day of _____, 20____ Notary Public _____ My commission expires _____	The statements made herein are certified to be true and correct: Name _____ Title _____ Date _____ Test No. _____

Figure 16:

SIZING AND PLACEMENT DATA

During the past years, various methods have been devised for the sizing of water hammer arresters. These varied sizing methods have created confusion among engineers, contractors and other persons engaged in the plumbing industry.

Standardization

The members of the Plumbing and Drainage Institute were aware of the difficulties encountered in the application of the different sizing methods. Therefore, they engaged in a research and testing program with the intention of producing one standardized method of sizing and placement - a method which would be of benefit to the entire plumbing industry. The final results are listed in this manual.

Symbols

Before the subject of a proposed sizing method can be explained it is first necessary to devise a code of symbols for the 7 different sized units required for average plumbing systems. Each unit must have a different size and capacity to control shock in piping systems of varied size and scope. The following symbol listing has been devised to denote the range in sizes for water hammer arresters, "AA" is the smallest sized unit - "F" represents the largest unit.

P.D.I. Symbols: AA-A-B-C-D-E-F

Comment

The P.D.I. symbols established above correspond to those units covered by the certification testing program and shall be used with all data on sizing and placement presented in this manual.

Sizing and Placement Data

Single and Multiple Fixture Branch Lines

Single and Multiple Fixture Branch Lines A method of sizing, based upon fixture units has been established as most appropriate because it is quick, accurate and well known. Most engineers use fixture-units for sizing water distribution systems.

Definition of Fixture-Unit

The National Plumbing Code offers this definition: "A fixture-unit is a quantity in terms of which the load producing effects on the plumbing system of different kinds of plumbing fixtures are expressed on some arbitrarily chosen scale." The following fixture-unit table is based upon information offered in the National Plumbing Code.

"Public" fixtures, are those found in public comfort stations, general toilet rooms, office buildings, and other buildings in which each fixture is open and accessible for use at all times. "Private" fixtures are those in residential areas not freely accessible such as in private homes, residential apartments, hotel guest rooms, private rooms or apartments in residential hotels or dormitories, and the like.

Notes

The fixture-unit values shown in the cold and hot water columns of Table IV are utilized in the sizing of water hammer arresters. Additional information on varied types of fixtures and their assigned fixture-unit values are contained in the appendix at the back of this standard.

Comment

These are the basic fixture-unit data which most engineers utilize to size their water distribution systems. These data can be used in the sizing and placement of engineered water hammer arresters at the same time that the piping systems are sized.

Sizing and Placement Data

In most installations where there are several fixtures, usually only one fixture valve at a time will be closed. Nevertheless, occasionally two or more fixture valves could be closed at the same instant. Table V, on sizing and selection, takes into consideration all design factors including simultaneous usage, pipe size, length, flow pressure and velocity. Table V, therefore, provides an easy, accurate method of determining the proper sized water hammer arrester for each multiple fixture branch line, and automatically provides for all factors which must be considered or otherwise calculated.

When the weight in “fixture-units” for cold and hot water branch lines serving a group of fixtures has been determined, this data can be applied to Table V.

Note: Ideally the flow pressure in branch lines serving fixtures should never exceed 55 p.s.i.g. Pressure reducing valves should be installed to maintain proper pressure. When, however, the

flow pressure exceeds 65 p.s.i.g., the next larger size water hammer arrester should be selected.

If the Fixture-unit total has a ½ fraction, it is to be rounded up to the next larger, or whole number. Thus, if the total is 11½ fixture-units, change it to 12 fixture-units.


TABLE IV

Fixture	Type of Supply Control	Weight in Fixture - Units					
		Public			Private		
		Total	C.W.	H.W.	Total	C.W.	H.W.
Water Closet 1.66 PF	Flush Valve	8	8	-	5	5	-
Water Closet 1.66 PF	Flush Tank	5	5	-	2.5	2.5	-
Pedestal Urinal 1.06 PF	Flush Valve	4	4	-	-	-	-
Stall or Water Urinal	Flush Valve 1.06 PF	4	4	-	-	-	-
Stall or Water Urinal	Flush Tank 1.06 PF	2	2	-	-	-	-
Lavatory	Faucet	2	1-½	1-½	1	1	1
Bathtub	Faucet	4	2	3	2	1-½	1-½
Shower Head	Mixing Valve	4	2	3	2	1	2
Bathroom Group	Flush Valve Closet	-	-	-	8	8	3
Bathroom Group	Flush Tank Closet	-	-	-	6	6	3
Separate Shower	Mixing Valve	-	-	-	2	1	2
Service Sink	Faucet	3	3	3	-	-	-
Laundry Tubs (1-3)	Faucet	-	-	-	3	3	3
Combination Fixture	Faucet	-	-	-	3	3	3

TABLE V

P.D.I. Units	AA	A	B	C	D	E	F
FIXTURE-UNITS	1-3	1-11	12-32	33-60	61-113	114-154	155-330


Examples



Cold Water Branch
 2 W.C. at 10 F.U. ...ea.=20
 4 Lav. at 1½ F.U. ...ea.= 6
 Total 26
 Select P.D.I. “B” Unit

Hot Water Branch
 4 Lav. at 1½ F.U. ea.= 6
 Total 6
 Select P.D.I. “A” Unit

Example 1:



Cold Water Branch
 2 W.C. at 10 F.U. ...ea.=20
 2 Ur. At 5 F.U. ...ea.=10
 4 Lav. at 1½ F.U. ...ea.= 6
 Total 36
 Select P.D.I. “C” Unit

Hot Water Branch
 4 Lav. at 1½ F.U. ea.= 6
 Total 6
 Select P.D.I. “A” Unit

Example 2:

Table V will permit engineers and contractors to select the proper water hammer arrester for each application. The following examples show the relative ease with which sizing can be accomplished using Tables IV and V.

It is relatively easy to select the proper sized water hammer arrester for a multiple fixture branch. Fig. 17 represents a typical riser diagram of the type that an engineer may include with his set of drawings.

When sizing the cold and hot water branch lines, it is usual practice to obtain the total number of fixture-units on each branch line. This information is then applied to sizing charts to determine the required size of the branch lines.

The proper sized water hammer arresters can be selected once the total of fixture-units for a cold or hot water branch line is known. It is only necessary to apply the fixture-units to Table V and select the appropriate water hammer arrester.

It is suggested that the engineers employ P.D.I. symbols for his riser diagrams, as shown in Figure 17. This practice will enable manufacturers to furnish the correct units.

It has been established that the preferred location for the water hammer arrester is at the end of the branch line between the last two fixtures served. This location is shown in Fig. 18.




Figure 17:

The location of the water hammer arresters shown in Fig. 18 applies to branch lines that do not exceed 20' in length, from the start of the horizontal branch line to the last fixture supply on this branch line. When the branch line exceeds the

20' length, an additional water hammer arrester should be used. This practice is best defined by two rules which have been established to cover the placement of water hammer arresters. These rules are explained below.





Figure 18: Illustration

RULE 1

Rule 1, covers multiple fixture branch lines which do not exceed 20' in length.




EXPLANATION – Fixture – unit sizing

Table V is used to select the required P.D.I. unit. See example

RULE 2

Rule 2, covers multiple fixture branch lines which do exceed 20' in length




EXPLANATION – Fixture – unit sizing

Table V is used to select the required P.D.I. unit. The sum of the F.U. ratings of units X and Y shall be equal to or greater than the demand of the branches. See example


Figure 19: Illustration

EXAMPLE OF RULE 1




C.W. = 26 F.U.
Needs – P.D.I. “B” Unit
H.W. = 6 F.U.
Needs – P.D.I. “A” Unit

EXAMPLE OF RULE 2



C.W. = 70 F.U.
Needs – P.D.I. “D” Unit

Examples of Rule 1:



Examples of Rule 2:




Figure 20: Note: There are practical limits concerning the overall length of a branch line. In a remote instance where a very long line branch line is involved, the general supply is generally fed to some mid-point or other location on the branch line as shown.



Figure 21:

Long Runs of Piping to Equipment

The majority of sizing and selection applications will involve single and multiple fixture branch lines. These are easily handled with Table V. The remainder of applications involve individual runs of piping to a remote item of equipment. The properly sized water hammer arresters for such applications can be determined by Table VI and Table VI-A.

Note: Ideally the flow pressure in branch lines serving fixtures should never exceed 55 p.s.i.g. Pressure reducing valves should be installed to maintain proper pressure. When, however, flow pressures of 65 to 85 p.s.i.g. are used, the next larger size water hammer arrester should be selected. Refer to Table VI-A. The recommendations for sizing and placement of arresters are based on experience of the industry.

Long Runs of Piping

When long runs of piping are employed to serve a remote item of equipment, the water hammer arrester should be located as close as possible to the point of quick closure. At this location, the water hammer arrester will control the developed energy and prevent the shock wave from surging through the piping system. A typical example of placement is given in Fig. 21.

EXAMPLES, defining the sizing and placement of water hammer arresters for single fixture and equipment branch lines are illustrated in Figures 22-26. For the sake of clarity, control valves, vacuum breakers and other necessary devices have been omitted in the illustrations.

TABLE VI						
WATER PRESSURES UP TO 65 P.S.I.G.						
P.D.I. WATER HAMMER ARRESTERS						
Nominal Pipe Diameter						
Length of Pipe	1/2"	3/4"	1"	1-1/4"	1-1/2"	2"
25	A	A	B	C	D	E
50	A	B	C	D	E	F
75	B	C	D	AE	F	EF
100	C	D	E	F	CF	FF
125	C	D	F	AF	EF	EFF
150	D	E	F	DF	FF	FFF

TABLE VI-A						
WATER PRESSURES 65 P.S.I.G. TO 85 P.S.I.G.						
P.D.I. WATER HAMMER ARRESTERS						
Nominal Pipe Diameter						
Length of Pipe	1/2"	3/4"	1"	1-1/4"	1-1/2"	2"
25	B	B	C	D	E	F
50	B	C	D	E	F	CF
75	C	D	E	F	CF	FF
100	D	E	F	CF	EF	EFF
125	D	E	CF	DF	FF	BFFF
150	E	F	CF	FF	DFF	FFFF




Figure 22:




Figure 23:




Figure 24:




Figure 25:




Figure 26:

APPENDIX A

RECOMMENDED RULES FOR SIZING THE WATER SUPPLY SYSTEM

Because of the variable conditions encountered it is impractical to lay down definite detailed rules of procedure for determining the sizes of water supply pipes in an appendix which must necessarily be limited in length. For a more adequate understanding of the problems involved, the reader is referred to Water-Distributing Systems for Buildings, Report BMS 79 of the National Bureau of Standards; and Plumbing Manual, Report BMS 66, also published by the National Bureau of Standards.


The following is a suggested order of procedure for sizing the water supply system.

A1 Preliminary Information

A1.1 Obtain the necessary information regarding the minimum daily service pressure in the area where the building is to be located.

A1.2 If the building supply is to be metered, obtain information regarding friction loss relative to the rate of flow for meters in the range of sizes, likely to be used. Friction loss data can be obtained from most manufactures of water meters. Friction losses for disk type meters may be obtained from Chart A-1.

A1.3 Obtain all available local information regarding the use of different kinds of pipe with respect both to durability and to decrease in capacity with length of service in the particular water supply.



A2 Demand Load

A2.1 Estimate the supply demand for the building main and the principal branches and risers of the system by totaling the fixture units on each, Table A-2, and then by reading the corresponding ordinate from Chart A-2 or A-3, whichever is applicable.

A2.2 Estimate continuous -supply demands in gallons per minute for lawn sprinklers, air conditioners, etc., and add the sum to the total demand for fixtures. The result is the estimated supply demand for the building supply.

TABLE A-2

Demand weight of fixtures in fixture-units ¹				
Fixture type ²	Weight in fixture - units ³		Minimum cold water	Connections hot water
	private	public		
Bathtub	2	4	1/2	1/2
Bedpan		10	1	
Bidet	2	4	1/2	1/2
Combination sink and tray	3		1/2	1/2
Dental unit or cuspidor		1	3/8	
Dental lavatory	1	2	1/2	1/2
Drinking fountain	1	2	3/8	
Kitchen sink	2	4	1/2	1/2
Lavatory	1	2	3/8	3/8
Laundry tray (1 or 2 compartments)	2	4	1/2	1/2
Shower, each head ⁴	2	4	1/2	1/2
Sink; Service	2	4	1/2	1/2
Urinal, pedestal		4	1	
Urinal (wall lip)		4	1/2	
Urinal stall		4	3/4	
Urinal with flush tank		2		
Urinal trough (for every 2 foot section)		2	1/2	
Wash sink, circulator or multiple (each set of faucets)		2	1/2	1/2
Water Closet: F.V.	6	10	1	
Tank	3	5	3/8	

¹ For supply outlets likely to impose continuous demands, estimate continuous supply separately and add to total demand for fixtures.

² For fixtures not listed, weights may be assumed by comparing the fixture to a listed one using water in similar quantities and at similar rates.

³ The given weights are for total demand for fixtures with both hot and cold water supplies. The weights for maximum separate demands may be taken as seventy-five (75) percent of the listed demand for the supply.

⁴ Shower over bathtub does not add fixture unit to group.

A3 Permissible Friction Loss

A3.1 Decide what is the desirable minimum pressure that should be maintained at the highest fixture in the supply system. If the highest group of fixtures contains flush valves, the pressure for the group should not be less than fifteen (15) psi. For flush tank supplies, the available pressure may be not less than eight (8) psi.

A3.2 Determine the elevation of the highest fixture or group of fixtures above the water (street) main. Multiply this difference in elevation by forty-three hundredths (0.43). The result is the loss in static pressure in psi (pounds per square inch).

A3.3 Subtract the sum of loss in static pressure and the pressure to be maintained at the highest fixture from the average minimum daily service pressure. The result will be the pressure available for friction loss in the supply pipes, if no water meter is used. If a meter is to be installed, the friction loss in the meter for the estimated maximum demand should also be subtracted from the service pressure to determine the pressure loss available for friction loss in the supply pipes.

A3.4 Determine the developed length of pipe from the water (street) main to the highest fixture. If close estimates are desired, compute with the aid of Table A-3 the equivalent length of pipe for all fittings in the line from the water (street) main to the highest fixture and

add the sum to the developed length. The pressure available for friction loss in pounds per square inch, divided by the developed lengths of pipe from the water (street) main to the highest fixture, times one hundred (100), will be the average permissible friction loss per one hundred (100) foot length of pipe.

A4 Size Of Building Supply

A4.1 Knowing the permissible friction loss per one hundred (100) feet of pipe and the total demand, the diameter of the building supply pipe may be obtained from Charts A-4, A-5, A-6 or A-7, whichever is applicable. The diameter of pipe on or next above the coordinate point corresponding to the estimated total demand and the permissible friction loss will be the size needed up to the first branch from the building supply pipe.

A4.2 If copper tubing or brass pipe is to be used for the supply piping, and if the character of the water is such that only slight changes in the hydraulic characteristics may be expected, Chart A-4 may be used.

A4.3 Chart A-5 should be used for ferrous pipe with only the most favorable water supply as regards corrosion and caking. If the water is hard or corrosive, Charts A-6 or A-7 will be applicable. For extremely hard water, it will be advisable to make additional allowances for the reduction of capacity of hot water lines in service.

TABLE A-3

Equivalent length of pipe for various fittings							
Diameter of fitting (inches)	90 standard elbow	45 standard elbow	standard T 90	Coupling or straight run of T	Gate valve	Globe valve	Angle Valve
	Feet	Feet	Feet	Feet	Feet	Feet	Feet
3/8	1	0.6	1.5	0.3	0.2	8	4
1/2	2	1.2	3	0.6	0.4	15	8
3/4	2.5	1.5	4	0.8	0.5	20	12
1	3	1.8	5	0.9	0.6	25	15
1-1/4	4	2.4	6	1.2	0.8	35	18
1-1/2	5	3	7	1.5	1	45	22
2	7	4	10	2	1.3	55	28
2-1/2	8	5	12	2.5	1.6	65	34
3	10	6	15	3	2	80	40
4	14	8	21	4	2.7	125	55
5	17	10	25	5	3.3	140	70
6	20	12	30	6	4	165	80

A5 Size of Principal Branches and Riser

A5.1 The required size of branches and risers may be obtained in the same manner as the building supply by obtaining the demand load on each branch or riser and using the permissible friction loss computed in Section A3.

A5.2 Fixture branches to the building supply, if they are sized for the same permissible friction loss per one hundred (100) feet of pipe as the branches and risers to the highest level in the building, may lead to inadequate water supply to the upper floor of the building. This may be controlled by: (1) Selecting the sizes of pipe for the different branches so that the total friction loss in each lower branch is approximately equal to the total loss in the riser, including both friction loss and loss in static pressure; (2) by throttling each such branch by means of a valve until the preceding balance is obtained; (3) by increasing the size of the building supply and risers above the minimum required to meet the maximum permissible friction loss.

A6 General

A6.1 In general, a velocity greater than fifteen (15) feet per second in the main risers, or principal branches should not be employed, as objectionable line noise is likely to result.

A6.2 If a pressure reducing valve is used in the building supply, the developed length of supply piping and the permissible friction loss should be computed from the building side of the valve.

A6.3 The allowances in Table A-3 for fittings are based on non-recessed threaded fittings. For recessed threaded fittings and streamlined soldered

fittings, one-half (1/2) the allowances given in the table will be ample.

A7 Example

A7.1 Assume an office building of four (4) stories and basement; pressure on the building side of the pressure-reducing valve of fifty-five (55) psi; an elevation of highest fixture above the pressure-reducing valve of forty-five (45) feet; a developed length of pipe from the pressure-reducing valve to the most distant fixture of two hundred (200) feet; and the fixtures to be installed with flush valves for water closets and stall urinals as follows:

Allowing for fifteen (15) psi at the highest fixture under maximum demand of three hundred and ten (310) gallons per minute (see Table A-4), the pressure applicable for friction loss is found by the following:

$$55 - \{ 15 + (45 \times 0.43) \} = 20.65 \text{ psi}$$

The allowable friction loss per one hundred (100) feet of pipe is therefore

$$100 \times 20.65 \div 200 = 10.32 \text{ psi}$$

If the pipe material and water supply are such that Chart A-5 applies, the required diameter of the building supply is three (3) inches, and the required diameter of the branch to the hot-water heater is two (2) inches.

The sizes of the various branches and risers may be determined in the same manner as the size of the building supply or the branch to the hot water system - by estimating the demand for the riser or branch from Charts A-2 or A-3, and applying the total demand estimate for the branch, riser or section thereof, to the appropriate flow chart.

Table A-4						
Fixture Units and Estimated Demands						
	Building supply			Branch to hot-water system		
Fixture	No. of fixtures	Fixture units	Demand (gallons per minute)	No. of fixtures	Fixture units	Demand (gallons per minute)
Water Closets	130	1,300				
Urinals	30	150				
Shower Heads	12	48		12		(12x4)x3/4=36
Lavatories	130	260		130		(130x2)x3/4=195
Service Sinks	27	81		27		(27x3)x3/4=61
Total		1,839	310		292	86

SIZING WATER SYSTEMS

CHART A-2
Estimated Curves for Demand Load




CHART A-3
Enlarged Scale Demand Load




CHART A-4




CHART A-5




CHART A-6





CHART A-7



1. KITCHEN AREAS							
FIXTURE OR EQUIPMENT	TOTAL	C.W.	H.W.	FIXTURE OR EQUIPMENT	TOTAL	C.W.	H.W.
Baine Marie	2	-	2	Sink, Dish Soak (non-mobile)	3	2 1/2	2 1/2
Carbonator	1	1/2	-	Sink, Meat Preparation	3	2 1/2	2 1/2
Coffee Urn Stand	2	2	-	Sink, Pot and Pan, (per faucet)	4	3	3
Cold Pan	1	1	-	Sink, Salad Preparation	3	2 1/2	2 1/2
Compressor, Refrigerator	1	1	-	Sink, Silver Soak	3	2 1/2	2 1/2
Grinder, Food Waste	3	3	-	Sink, Vegetable	3	2 1/2	2 1/2
Hose, Pre-Rinse	3	2 1/2	2 1/2	Soda Fountain Unit	1	1/2	-
Hose Station	4	3	3	Steam Table	2	-	2
Ice Maker	1	-	-	Tray Make-up Table	2	2	2
Kettle Stand	2	2	2	Washer, Bottle with jet rinsers	2	2	-
Milk Dispenser	1	-	1	Washer, Can	6	6	6
Peeler, Vegetable	3	-	1	Washer, Glassware	4	1 1/2	3
Sink, Back Bar	2	1 1/2	1 1/2	Washer, Nipple	2	1 1/2	1 1/2
Sink, Baker's Pan	3	2 1/2	2 1/2	Washer, Pot and Pan	6	-	6
Sink, Cook's	3	2 1/2	2 1/2	Washer, Silver	2	-	2
Sink, Diet Kitchen	2	1 1/2	1 1/2	Water Station	1	1	-
				Soup Kettle	2	1 1/2	1 1/2
2. OTHER AREAS							
FIXTURE OR EQUIPMENT	TOTAL	C.W.	H.W.	FIXTURE OR EQUIPMENT	TOTAL	C.W.	H.W.
Condenser, Drinking Fountain	1	1	-	Hose, Bibb, Interior	4	4	-
Condenser, Refrigeration	1	1	-	Wall Hydrant	4	4	-
Ice Cuber and Flakers	1	1	-	Wall Hydrant, C.W. and H.W	4	3	3
3. HOSPITAL AND LABORATORY AREAS							
FIXTURE OR EQUIPMENT	TOTAL	C.W.	H.W.	FIXTURE OR EQUIPMENT	TOTAL	C.W.	H.W.
Aspirator	2	2	-	Sink, Animal Area	4	2	2
Autopsy Table, Complete	4	3	2	Sing, Barium	3	2 1/2	2 1/2
Autopsy Table, Aspirator	2	2	-	Sink, Central Supply	3	2 1/2	2 1/2
Autopsy Table, Flushing Hose	2	2	-	Sink, Clean-up room	3	2 1/2	2 1/2
Autopsy Table, Flushing Rim	3	3	-	Sink, Clinical	10	10	3
Autopsy Table, Sink Faucet	3	2 1/2	2 1/2	Sink, Clinical, Bed Pan Hose	10	10	4
Autopsy Table, Waste Disposal	1 1/2	1 1/2	-	Sink, Cup	1	1	-
Bath, Arm	4	2	3	Sink, Floor	4	3	3
Bath, Emergency	4	2	3	Sink, Formula Room	4	3	3
Bath, Immersion	20	7	15	Sink, Laboratory	2	1 1/2	1 1/2
Bath, Leg	10	4	7	Sink, Laboratory and Trough	3	2 1/2	1 1/2
Bath, Sitz	4	2	3	Sink, Mop	3	3	3
Bedpan Washer, Steam	10	10	-	Sink, Pharmacy	2	1 1/2	1 1/2
Bidet	4	3	3	Sink, Plaster	4	3	3
Cleaner, Sonic	3	2 1/2	2 1/2	Sink, Nurse's Station	2	1 1/2	1 1/2
Cuspidor, Dental and Surgical	1	1	-	Sink, Scrub-up	4	3	3
Cuspidor, Dental Chair	1	1	-	Sink, Clean Utility	3	2 1/2	2 1/2
Drinking Fountain	1	1	-	Sink, Soiled Utility	3	2 1/2	2 1/2
Floor Drain, Flushing Type	10	10	-	Sterilizer, Boiling Instrument	2	-	2
Hose, Bed Pan General	2	1 1/2	1 1/2	Sterilizer, Boiling Utensil	2	-	2
Hose, Bed Pan Private	1	1	1	Sterilizer, Pressure Instrument	2	2	-
Lavatory, Barber	2	1 1/2	1 1/2	Sterilizer, Water	5	5	2
Lavatory, Dental	1	1	1	Washer Sterilizer	6	6	-
Lavatory, Nursery	2	1 1/2	1 1/2	Washer, Flask	4	-	4
Lavatory, Scrub-up	2	1 1/2	1 1/2	Washer, Formula Bottle	4	4	-
Lavatory, Treatment	1	1	1	Washer, Glove	4	3	3
Microscope, Electron	1	1	-	Washer, Needle	2	2	-
Sanitizer, Boiling Instrument	2	-	2	Washer, Pipette	4	3	3
Sanitizer, Boiling Utensil	2	-	2	Washer, Syringe	4	-	4
Shower, Obstetrical	4	2	3	Washer, Tube	4	4	-

Abstracted from "A Guide to Hospital Plumbing" by Lawrence Guss, Air Conditioning, Heating & Ventilating, October 1961.

DEFINITIONS

1. **Air Chamber** A closed section of pipe or other container designed to trap air at atmospheric pressure mounted vertically in a tee in a water supply line intended to reduce water hammer pressures.
2. **Air Chamber, Calculate** An air chamber designed in accordance with the Dawson & Kalinske formula for reducing water hammer pressures.
3. **Atmospheric Pressure** Pressure, in lbs. per sq. in., atmospheric air above absolute zero pressure at ambient conditions (14.7 psi or 0.0 psig at standard conditions).
4. **Branch Line** A water supply line connecting one or more fixtures to a water supply main, riser or other branch.
5. **Calculated Air Chamber** See Air Chamber, Calculated.
6. **Fixtures** Sanitary plumbing fixture or related item of equipment which can demand water from a branch line.
7. **Fixture Unit** See definition on Page 19.
8. **Flowing Pressure** The gage pressure in a flowing plumbing supply line immediately upstream of a fixture valve.
9. **Gage Pressure** Pressure, in lbs. per sq. in., above atmospheric indicated by a pressure gage.
10. **Fps.** Feet per second.
11. **F.U.** Fixture Unit.
12. **G.P.M.** U.S. Gallons per minute.
13. **Kinetic Energy** Energy available from a flowing column of water due to its velocity.
14. **P.D.I.** The Plumbing and Drainage Institute.
15. **Point of Relief** Point of Relief is a larger mass of water in the system, to which the branch is connected. Point of Relief could be a larger diameter main or riser, water tank, or hot water boiler. A larger diameter pipe is a main, which is at least two (2) nominal pipe sizes larger than the branch line in question. See also page 4, paragraph titled "Reaction."
16. **Pressure Transducer** A pressure sensitive device that will produce an electric signal proportional to the pressure to which it is subjected, the signal being capable of amplification.
17. **P.S.I.** Pounds per Square Inch.
18. **P.S.I.G.** Pounds per Square Inch Gage; pounds per square Inch above atmospheric pressure.
19. **Reaction** See Page 4.
20. **Remote Fixture** A single fixture located on a branch line at a distance from the upstream end of the branch line.
21. **Residual Pressure** Same as flowing pressure.
22. **Riser** A water supply main in a building conducting water vertically from one floor to another.
23. **Shock** The force generated in a piping system by water hammer.
24. **Shock Absorber** Water Hammer Arrester.
25. **Shock Intensity** See Page 4.
26. **Static Pressure** The pressure in lbs. per sq. in., in a dormant or non-flowing branch line.
27. **Surge** The pressure increase, in lbs. per sq. in., in a branch line caused by water hammer.
28. **Surge Pressure** The maximum pressure, in lbs. per sq. in. gage, in a branch line caused by rapid valve closure.
29. **Water Hammer** See Page 4.
30. **Water Hammer Arrester** A device other than an air chamber or calculated air chamber designed to provide continuous protection against excessive surge pressure.
31. **Waterlogged** Condition of an air chamber when all or part of its normal air content has been displaced by water.
32. **Total Pressure** The sum of the surge and flow pressures.

